

## **Lossnoy** Unit Maintenance Sheet

Complete one form per unit

The Renewable Solutions Provider Making a World of Difference

Contractor Name:		Site Name:		
Engineer's Name:	Site No:	·	Date of Visit:	
	Los	snay Unit Details		
Model No:	Serial No:		Area Served	
	Lo	ssnay Checklist		
Tasks		Frequency	Tick box or record reading	
Clean Lossnay unit filters		Every Visit		
Clean Lossnay unit core		Every Visit		
Check inside the unit for any visual signs of water or moisture				
Check fan motor and blade visual inspection				
Check operation of bypass damper				
Check supply air outlet has adequate air flow				
Check exhaust air outlet has adequate air flow				
Check return air inlet has adequate air flow				
Check outside air inlet has adequate air flow				
Check electrical connections are made and secure		Every Visit		
Check controls operation		Every Visit		
Check thermistor readings are accurate		Every Visit		
		<u>.</u>		
			Additional Notes and Tasks Carried Out	



Air Conditioning | Heating Ventilation | Controls

Frequency of Visits:
Every Visit – Minimum of 4 visits per year
Mitsubishi Electric recommends that the frequency of maintenance visits be no less than four per annum.

Frequency of maintenance may increase dependent upon the equipment's environment.

Failure to maintain the system to above the minimum recommendations could result in the warranty becoming null and void.

Monitor system, save and record all data.